ENVIRONMENTAL
TESTING SERVICES LLC

Lead and Copper in Drinking Water Sampling

Tiny Tots Spot

112 Lee Ave, New Brunswick, NJ 08901

Inspection Company:
Environmental Testing Services LLC.
619 Wills Ave.
Deptford, NJ 08096

Laboratory:
Accurate Analytical Testing, LLC.
30105 Beverly Road,
Romulus MI 48174

Lead in Drinking Water Sampling Date:
Initial: May 21st, 2021
Follow up: July 20th, 2021

Licensed State Lead Inspector
Risk Assessor
Michael Stefkovic (License # NJ 034560)

July 20th, 2021

Tiny Tots Spot
112 Lee Ave.
New Brunswick, NJ 08901

Re: Lead and Copper in Drinking Water Sampling
112 Lee Ave, New Brunswick, NJ 08901.

Dear Client:

Environmental Testing Services, LLC. provided water testing for lead and copper on May 21st, 2021 and a follow up water test on July 20th, 2021.

The purpose of this project was to sample the school's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test shows lead and copper amounts exceeding the EPA limit of 15 ug/L for lead and 1300 ug/L for Copper. The locations of each testing location were given to the inspector earlier as to where the use of each water source frequently used.

Samples were collected in 250 ml bottles. Samples were immediately transported to Accurate Analytical Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

Results of the sampling found that all of the water sources tested fell under the EPA limit of 15 ug/L.

Sample analysis results and the chain of custody are attached to this report.
If you should have any questions, please feel free to contact us at (856) 432-4468

Sincerely,

Michael Stefkovic,
President

Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to EMSL Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." ***For water****, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*
The results from the lab are given in ug/L.

Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.

Wipe Sample	Sampling Location Description	Laboratory Results LEAD (ug/L)	Laboratory Results COPPER (ug/L)	
A-1	Kitchen Sink	<1.0 - PASS	7.2 PASS	
A-2	Girls Bathroom	<1.0 - PASS	18.1- PASS	
A-3	Boys Bathroom	<1.0 - PASS	10.0- PASS	
A-4	3FL BATH 1	6.7 - PASSED	11.8- PASS	
A-5	3FL BATH 2	<1.0 - PASS	53.6- PASS	
A-6	3FL GIRLS BATH	3.4- PASS	65.1- PASS	
A-7	2FL BOYS BATH	5.3 PASSED	36.2- PASS	
A-8	3FL CLASS SINK	20.9- FAILED	184.6- PASS	
	FOLLOW UP WATER TEST 7.20.2021			
B1	3rd FL Class Sink	9.8 PASS		

1. **The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L.**
2. **The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L.**

LAB Results

Lead in Drinking water report.

ACCURATE ANALYTICAL TESTING LLC

30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services
619 Wills Ave.
Deptford, NJ 08096
Attn : Mike Stefkovic **Email :** lead@ets-enviro.com
Phone : 215-432-4468 **Fax :**

Client Project : TINY TOTS **Collected By:** NA

Project Location : 112 LEE AVE NEW BRUNSWICK NJ 08901

AAT Project : 676101
Sampling Date : 05/21/2021
Date Received : 05/24/2021
Date Analyzed : 05/26/2021
Date Reported : 5/27/2021 4:00:00AM
WSSN :

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
6419602	A1	KIT SINK	PB CO	NA	<1.0	1.0	Below
6419603	A2	GIRLS BATH	PB CO	NA	<1.0	1.0	Below
6419604	A3	BOYS BATH	PB CO	NA	<1.0	1.0	Below
6419605	A4	3FL BATH 1	PB CO	NA	6.7	1.0	Below
6419606	A5	3FL BATH 2	PB CO	NA	<1.0	1.0	Below
6419607	A6	3FL GIRLS BATH	PB CO	NA	3.4	1.0	Below
6419608	A7	2FL BOYS BATH	PB CO	NA	5.3	1.0	Below
6419609	A8	3FL CLASS SINK	PB CO	NA	20.9	1.0	Above

Analyst Signature

Norman Cyr

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
For true values assume (2) significant figures. AAT Internal SOP 5230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
Date Printed: 05/27/2021 AAT Project: 676101

Copper in Drinking water

ACCURATE ANALYTICAL TESTING LLC

30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services
619 Wills Ave.
Deptford, NJ 08096
Attn : Mike Stefkovic **Email :** lead@ets-enviro.com
Phone : 215-432-4468 **Fax :**

AAT Project : 676101
Sampling Date : 05/21/2021
Date Received : 05/24/2021
Date Analyzed : 05/26/2021
Date Reported : 5/27/2021 4:00:00AM

Client Project : TINY TOTS **Collected By :** NA **WSSN :**
Project Location : 112 LEE AVE NEW BRUNSWICK NJ 08901

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
6419602	A1	KIT SINK	PB CO	NA	7.2	Below
6419603	A2	GIRLS BATH	PB CO	NA	18.1	Below
6419604	A3	BOYS BATH	PB CO	NA	10.0	Below
6419605	A4	3FL BATH 1	PB CO	NA	11.8	Below
6419606	A5	3FL BATH 2	PB CO	NA	53.6	Below
6419607	A6	3FL GIRLS BATH	PB CO	NA	65.1	Below
6419608	A7	2FL BOYS BATH	PB CO	NA	36.2	Below
6419609	A8	3FL CLASS SINK	PB CO	NA	184.6	Below

Analyst Signature

Norman Cyr

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results
relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.
All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

Lab ID #100986

FOLLOW UP TEST 7.20.21

ACCURATE ANALYTICAL TESTING LLC

30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services
619 Wills Ave.
Deptford, NJ 08096
Attn : Mike Stefkovic Email : lead@ets-enviro.com
Phone : 215-432-4468 Fax :

AAT Project : 696150
Sampling Date : 07/20/2021
Date Received : 07/21/2021
Date Analyzed : 07/23/2021
Date Reported : 7/23/2021 7:38:50AM

Client Project : TINY TOTS Collected By: M. STEFKOVIC WSSN :

Project Location : 112 LEE AVE NEW BRUNSWICK NJ 08901

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
6592840	B1	3RD FL CLASS SINK 250 ML	PB	NA	9.8	1.0	Below

Analyst Signature

Nathan Ditty

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
For true values assume (2) significant figures. AAT internal SOP 5230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

Accredited Laboratory Pb Lead Lab ID #100986

NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
Date Printed: 07/23/2021 AAT Project: 696150

ACCURATE ANALYTICAL TESTING LLC
30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-8407
Website: www.accurate-test.com
Email: customersupport@accurate-test.biz

AIHA LAP, LLC ACCREDITED LABORATORY

SUBMITTING COMPANY
Environmental Testing Services Llc
619 Wills Ave. Deptford, NJ 08096

CONTACT INFORMATION
Office: 866-226-2114
Fax:
Email 1:
Email 2:

CHAIN OF CUSTODY

PROJECT NUMBER: Tiny Tots SAMPLING DATE: 5 / 21 / 2021
PROJECT ADDRESS: 112 Lee Ave, New Brunswick NJ 08901
PERSON COLLECTING the SAMPLES:

REQUESTED ANALYSIS: Drinking Water
☐ LEAD ☐ COPPER ☒ BOTH
WSSN

TURNAROUND TIME (please check one)
24 Hour ( ) 48 Hour (XX)
72 Hour ( ) 5 Days ( )
If no TAT is indicated, default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME
607001	A1	Kitchen Sink	PB/CO		
	A2	Girls BATH			
	A3	Boys BATH			
	A4	3rd Floor BATH 1			
	A5	3rd Floor BATH-2			
	A6	3rd Floor Girls BATH			
	A7	2nd Floor Boys BATH			
	A8	3rd Floor CLASS SINK			

CLIENT COMMENTS
SAMPLES SHIPPED
SAMPLES ACIDIFIED Y N
NY STATE SAMPLES ☐ (Check here)

SAMPLE CONDITION
SEALS INTACT Y N
CONTAINERS LABELED Y N
RECVD & ACCEPTED Y N
SAMPLES ACIDIFIED Y N

LAB REMARKS
2009

LAB PROJECT NUMBER 07001

SAMPLES RELINQUISHED BY	SAMPLES RECEIVED BY	DATE	TIME
			AM PM
			AM PM

By submitting samples to AAT, the client agrees to AAT's terms and conditions.
AAT is not responsible for shipping delays

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

7041C-Drinking Water

Initital

ACCURATE ANALYTICAL TESTING LLC

30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-8407
Website: www.accurate-test.com
Email: customersupport@accurate-test.biz

AIHA LAP, LLC ACCREDITED LABORATORY

SUBMITTING COMPANY
Environmental Testing Services Llc
619 Wills Ave. Deptford, NJ 08098

CONTACT INFORMATION
Office: 866-226-2114
Fax:
Email 1:
Email 2 :

PROJECT NUMBER: Tiny Tots
PROJECT ADDRESS: 112 Lee Ave New Brunswick NJ 08901
PERSON COLLECTING the SAMPLES: M. Stefkovic
SAMPLING DATE: 7/20/21

REQUESTED ANALYSIS
Drinking Water
☒ LEAD
☐ COPPER
☐ BOTH
WSSN

TURNAROUND TIME (please check one)
24 Hour ( ) 48 Hour ( )
72 Hour (XX) 5 Days ( )
If no TAT is indicated, default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME
[illegible]	B1	3rd Fl Class Sink	PB		250

CLIENT COMMENTS
SAMPLES SHIPPED
SAMPLES ACIDIFIED Y N
NY STATE SAMPLES (Check here)

SAMPLE CONDITION
SEALS INTACT Y N
CONTAINERS LABELED Y N
RECVD & ACCEPTED Y N
SAMPLES ACIDIFIED Y N

LAB REMARKS

LAB PROJECT NUMBER 60A0150

SAMPLES RELINQUISHED BY	SAMPLES RECEIVED BY	DATE	TIME
[signature]	Dani Miller Accurate Analytical Testing	7/21	9 AM / PM

By submitting samples to AAT, the client agrees to AAT's terms and AAT is not responsible for shipping delays

* Sample Type or Purpose – Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

F041C-Drinking Water

Follow up

LEAD CERTIFICATIONS
ETS LLC.
STATE OF NJ