ENVIRONMENTAL
TESTING SERVICES LLC

Lead and Copper in Drinking Water Sampling

Tiny Tots Spot

192 Hale St, New Brunswick, NJ 08901

Inspection Company:
Environmental Testing Services LLC.
619 Wills Ave.
Deptford, NJ 08096

Laboratory:
Accurate Analytical Testing, LLC.
30105 Beverly Road,
Romulus MI 48174

Lead in Drinking Water Sampling Date:
May 21st, 2021

Licensed State Lead Inspector
Risk Assessor
Michael Stefkovic (License # NJ 034560)

May 21st, 2021

Tiny Tots Spot
192 Hale St.
New Brunswick, NJ 08901

Re: Lead and Copper in Drinking Water Sampling
192 Hale St, New Brunswick, NJ 08901.

Dear Client:

Environmental Testing Services, LLC. provided water testing for lead and copper on May 21st, 2021.

The purpose of this project was to sample the school's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test shows lead and copper amounts exceeding the EPA limit of 15 ug/L for lead and 1300 ug/L for Copper. The locations of each testing location were given to the inspector earlier as to where the use of each water source frequently used.

Samples were collected in 250 ml bottles. Samples were immediately transported to Accurate Analytical Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

Results of the sampling found that all of the water sources tested fell under the EPA limit of 15 ug/L.

Sample analysis results and the chain of custody are attached to this report.
If you should have any questions, please feel free to contact us at (856) 432-4468

Sincerely,

Michael Stefkovic,
President

Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to EMSL Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." ***For water****, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*
The results from the lab are given in ug/L.

Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.

Wipe Sample	Sampling Location Description	Laboratory Results LEAD (ug/L)	Laboratory Results COPPER (ug/L)	
B1	Boys Bath L Sink	<1.0 - PASS	56.6 PASS	
B2	Girls Bath R Sink	<1.0 - PASS	41.3 PASS	
B3	Kit Sink	<1.0 - PASS	46.5 PASS	

1. **The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L.**
2. **The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L.**

LAB Results

Lead in Drinking water report.

ACCURATE ANALYTICAL TESTING LLC
30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

REVISED REPORT

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services
619 Wills Ave.
Deptford, NJ 08096
Attn : Mike Stefkovic **Email :** lead@ets-enviro.com
Phone : 215-432-4468 **Fax :**

AAT Project : 676102
Sampling Date : 05/21/2021
Date Received : 05/24/2021
Date Analyzed : 05/26/2021
Date Reported : 6/17/2021 2:06:14PM

Client Project : TINY TOTS **Collected By:** NA
WSSN :
Project Location : 192 HALE ST NEW BRUNSWICK NJ 08901
Client Comment: +Updated address per client email

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
6419610	B1	BOYS BATH L SINK	PB CO	NA	<1.0	1.0	Below
6419611	B2	GIRLS BATH R SINK	PB CO	NA	<1.0	1.0	Below
6419612	B3	KIT SINK	PB CO	NA	<1.0	1.0	Below

Analyst Signature

Norman Cyr

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
Date Printed: 06/17/2021 AAT Project: 676102

Copper in Drinking water

ACCURATE ANALYTICAL TESTING LLC
30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

REVISED REPORT

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services
619 Wills Ave.
Deptford, NJ 08096
Attn : Mike Stefkovic **Email :** lead@ets-enviro.com
Phone : 215-432-4468 **Fax :**

AAT Project : 676102
Sampling Date : 05/21/2021
Date Received : 05/24/2021
Date Analyzed : 05/26/2021
Date Reported : 6/17/2021 2:06:14PM

Client Project : TINY TOTS **Collected By :** NA **WSSN :**
Project Location : 192 HALE ST NEW BRUNSWICK NJ 08901

Client Comment: +Updated address per client email

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
6419610	B1	BOYS BATH L SINK	PB CO	NA	56.6	Below
6419611	B2	GIRLS BATH R SINK	PB CO	NA	41.3	Below
6419612	B3	KIT SINK	PB CO	NA	46.5	Below

Analyst Signature

Norman Cyr

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
For true values assume (2) significant figures. AAT Internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 06/17/2021 AAT Project: 676102

CHAIN OF CUSTODY

ACCURATE ANALYTICAL TESTING LLC

30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-8407
Website: www.accurate-test.com
Email: customersupport@accurate-test.biz

AIHA LAP, LLC ACCREDITED LABORATORY

SUBMITTING COMPANY
Environmental Testing Services LLc
619 Wills Ave. Deptford, NJ 08098

CONTACT INFORMATION
Office: 866-226-2114
Fax:
Email 1:
Email 2 :

PROJECT NUMBER: Tiny Tots
PROJECT ADDRESS: 112 Lee Ave, New Brunswick NJ
PERSON COLLECTING the SAMPLES: 08901
SAMPLING DATE: 5 / 21 / 2021

REQUESTED ANALYSIS
Drinking Water
☐ LEAD
☐ COPPER
☒ BOTH
WSSN

TURNAROUND TIME (please check one)
24 Hour ( ) 48 Hour (X)
72 Hour ( ) 5 Days ( )
If no TAT is indicated, default is 5 Days

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME
	B1	Boys BATH left Sink	BD/CS		250 ml
	B2	Girls BATH Right Sink	↓		250 ml
	B3	Kitchen Sink			250 ml
	B4				
	B5				

CLIENT COMMENTS
SAMPLES SHIPPED
SAMPLES ACIDIFIED Y N
NY STATE SAMPLES (Check here)

SAMPLE CONDITION
SEALS INTACT Y N
CONTAINERS LABELED Y N
RECVD & ACCEPTED Y N
SAMPLES ACIDIFIED Y N

LAB REMARKS

LAB PROJECT NUMBER 6/7/22

SAMPLES RELINQUISHED BY	SAMPLES RECEIVED BY	DATE	TIME
AM			AM PM
			AM PM

By submitting samples to AAI, the client agrees to AAI's terms and conditions.
AAI is not responsible for shipping delays

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

LEAD CERTIFICATIONS
ETS LLC.
STATE OF NJ